
Weekly report

SNU


BongHo Kim

e+ beam line lens test




- Last week
- Lens focusing is checked with changing HV for three lens.
- Beam center is moved by lens focusing.
- Beam shape is like hole shape in last electrode (focusing is not working well)


e+ beam line (near antion chamber)



- Buncher is used for beam acceleration (~4.5kV)
- Lens is used for focusing by positive HV below 30kV by three lens
- MCP is installed with grid (front of MCP) to monitor beam profile and for energy scan
- Time distribution is tested with new switch in the end of BG trap (switch for beam dump)




Beam data without coil




5

PWO data




- With coil, PWO signal is also increased.
- No big different for HV value in Lens. (small increase)

Status in CEA




- Because I forgot to turn off coil, I have tried to repair coil to new wires.
- In proton beam line, we changed broken support frame to new one.
- We also modify Faraday cup support to change Faraday cup position. 2017-07-27 weekly meeting




2017-07-27

8

S-particle search (Y(1,2) \rightarrow S + Λ (+p, π , γ))



Missing mass (m(Y(1S)- Λ - Λ 1)



- Only two proton PID(p|pi) cut>0.4
- Almost no event is in missing mass distribution below 3GeV.

To do list

- Positron beam profile check with more coils in Antion chamber.
- Positron beam energy scan.
- Positron beam time distribution check.
- TOF simulation with 4mm thickness.
- S-particle search preparation.