

# **20170727 STATUS REPORT**

Ahram lee

# TOF Detector Preparation

DAQ system

Laptop did not boot last week...

Previous slide (05/18)

Dasan took the laptop to examine and recover on 05/10,  
but they called that it suddenly worked.  
And did not find any source of making a booting error.

It is working successfully, for sure about DAQRC program, and has no error.  
Although there is no loss of data,  
there is back-up of all DAQ data in external HDD.

After purchasing USB – Ethernet adapter, for internal network,  
Gain optimization will be started. (~ 2weeks)

# TOF Status

## : It has been installed and tested

Now we can use 12 counters.  
But DAQPC has **SAME booting problem**  
from yesterday.

Cosmic ray test

1. 6bar test(last week)
2. 12bar test

Gain adjustment

mthr=8


Gain check

mthr=8

**Event rate – threshold**

**mthr=4, 8, 24**







Time resolution



# TOF Status

## 12bar test

Module set :



Configuration : coincidence = 1x2x3x4  
for each FADC

mthr=4/8/24


th=100[ch]

delay = 0

# TOF Status

## 12bartest – (Event rate) vs (Threshold) #170~194

Coinc. = 1x2x3x4 for All FADCs  
mthr=4



# TOF Status

## DAQ notice – high rate error

Previous slide (07/20)

Module set : 1 2 3 4 (FADC 001)  
Configuration

- coincidence = 1x2+3x4
- mthr = 2
- (- default deadtime = 0 [ns])

∴ After 3560 trigger,  
DAQRC was stopped by error

∴ If two triggers are too close, a signal of a module cannot be saved → **ERROR!**  
Dead time should be set during high rate experiments.

The screenshot shows the GBAR Run Control interface. The terminal window displays a summary message and a traceback error: 'IndexError: list index out of range'. The 'Run Configuration' panel shows 'Run Type: test' and 'Run Desc:'. The 'Online Display' panel shows ADC Count plots for 'waveform\_1' and 'waveform\_3'. The 'Trigger Monitor' panel shows a high rate of triggers. The 'Run Summary' panel shows 'Current Time: 2017-07-15 00:37:07' and 'Rate [Hz]: 3792 [ 60.1 61.8 Hz]'. The terminal window also shows a table of module configurations: FADCT 2 4, ENABLED 1, CID 1 2 3 4, PID 5 6 7 8.

# TOF Status

## 12bartest – (Event rate) vs (Threshold) #170~194

Coinc. =  $1 \times 2 + 3 \times 4$  for All FADCs

mthr=8

, which means giving a trigger when any 4 bar(8ch) have a signal.

th=80[ch]	9.3Hz	→ ERROR (within 2min.)
th=100[ch]	8Hz	
th=200[ch]	7Hz	

# TOF Status

## 12bartest – (Event rate) vs (Threshold) #170~194

Coinc. = 1x2x3x4 for All FADCs

mthr=24

, which means giving a trigger when all bar have a signal.

th=5[ch]      0.5Hz



th=100[ch]    0.2Hz

# TOF Status

## Network registration

Previous slide (07/20)

Monitor PC – DAQ PC communication ?  
⇒ Remote Desktop Protocol (RDP) connection



# TOF Status

## Network registration

GBAR Network has been connected and now we can use it.  
To use GBAR Network, one should register a PC to IT support department.  
Temporarily, my personal Windows 10 Laptop is being registered.

< DAQ PC >



name	TOFPC001
outlet	0193-S:0205/02
IPv4	10.11.44.128

< Monitor PC (Temp.) >



name	GBARCRPC020
outlet	0093 2-0021
IPv4	10.11.44.129

A connection between DAQ – Monitor PC is already confirmed.  
For Remote Desktop Protocol connection, x-win32 is considered(recommended by CERN).

# CERN Status

1. Now we can use a power strip on a rack.

Total 10 outlets = 8 used + 2 left

3 for FADCs,

1 for TCB,

2 for hubs (USB/LAN)


1 for DAQPC

1 for HV modules

For now, it's enough, but later, we need more.

8 more FADCs

1 more for Desktop-Monitor



# CERN Status

1. Now we can use a power strip on a rack.
2. After all test is done, including MMC-TOF, we can move our detector to ASACUSA zone for antiproton beam. (Dip)