


Weekly Report

2019-07-16


Kim, Hanbeom

Detector Design Improvement (plan)

- New idea:




- Goal: reduce photon signal noise by vibration






Get rid of this part
(minor goal: Cu
mass reduction)


New detector module design - 190520






New detector module design – sensor




New detector module design – sensor



New detector module design – reflector -190624





New detector module design – reflector



- Heater Resistance: 1119 Ω


New detector module design – Au wiring

- Phonon




New detector module design – Au wiring


- Photon



On the photon sensor, the highly annealed wire is used, but it ran out before finishing wiring.



New detector module design – assembly




- Tower
- Some shortcomings:
 - Wire direction
 - Post height
 - Fixing method of reflector
 - ...

New detector module design

- Attachment of MMC & SQUID + Wiring - Done
- 4K Test – half done - Done
- Assembly of detector including clamp, wafer, and crystal - Done
- To make reflector - Done
- Test on RODY (refrigerator at IBS)
 - Now cooling...


New detector module design – refrigerator



New detector module design – refrigerator



2019-07-16



Low temp. meeting

- 190705 (Friday)
~6 hours


New detector module design – refrigerator cooling

1. Began pumping at 18:40, 190705
2. Compressor on 20:39
3. Liquid N₂ pre-cooling & exchange gas added



New detector module design – refrigerator cooling

1. Began pumping at 18:40, 190705
2. Compressor on 20:39
3. Liquid N₂ pre-cooling & exchange gas added
4. Monitoring (& stop pre-cooling)




190708 (Today) 9:42 a.m.

Temperature rose twice
- LN2 ran out → dewar change
(2 dewars were used.
Removed at 2:10 p.m. 190706)

New detector module design – refrigerator cooling

1. Began pumping at 18:40, 190705
2. Compressor on 20:39
3. Liquid N₂ pre-cooling & exchange gas added
4. monitoring



Main

Settings

Advanced

MaxiGauge

#	NAME	PRESSURE	STATUS
1	CH 1	2,00E-2 mbar	NO SENS
2	CH 2	2,00E-2 mbar	NO SENS
3	CH 3	2,00E-2 mbar	NO SENS
4	OVC	5,01E-4 mbar	UNDRANGE
5	IVC	2,87E-2 mbar	OK
6	STIL	5,10E-4 mbar	OK

Automatic mode pressure limits

Warning: These values influence the operation of the GHS in automatic mode. Please refer to

AVS47B (RS232 interface) - Disabled (C:\avs-47\LogAVS__2019-07-05-19-32-38.dat)

190708 (Today) 3:42 p.m.

Current Cooling Status

<

190708 (Today) 3:42 p.m.
Current Cooling Status

New detector module design – refrigerator cooling

1. Began pumping at 18:40, 190705
2. Compressor on 20:39
3. Liquid N₂ pre-cooling & exchange gas added
4. Monitoring (& stop pre-cooling)
 - To use heater to activate the exchange gas
5. Zero field cooling – Jul. 8th~9th
6. SQUID Tuning (@ < 5 K) - 9th
7. Condensing – 9th~10th
8. MMC field insertion – 10th
9. PID (20 mK) started & getting data signals – doing Now